

C-STORE CONTRACTING
32 San Remo Dr.
S. Burlington, VT 05403
802-862-2500
Fax 802-864-6234

Leak Detector Test

Site _____ Site Number _____
Address _____
Date _____

Product _____ PASS FAIL
Leak Detector Type _____
Drain Line Pressure to Zero Yes No
Adjust Flow Meter to 3 Gal/Hr. Yes No
Pressure on Leak Detector in Leak Detect Mode _____
Time in Leak Detect Mode at Operating Pressure _____
Name _____ Date _____

Product _____ PASS FAIL
Leak Detector Type _____
Drain Line Pressure to Zero Yes No
Adjust Flow Meter to 3 Gal/Hr. Yes No
Pressure on Leak Detector in Leak Detect Mode _____
Time in Leak Detect Mode at Operating Pressure _____
Name _____ Date _____

Product _____ PASS FAIL
Leak Detector Type _____
Drain Line Pressure to Zero Yes No
Adjust Flow Meter to 3 Gal/Hr. Yes No
Pressure on Leak Detector in Leak Detect Mode _____
Time in Leak Detect Mode at Operating Pressure _____
Name _____ Date _____

Product _____ PASS FAIL
Leak Detector Type _____
Drain Line Pressure to Zero Yes No
Adjust Flow Meter to 3 Gal/Hr. Yes No
Pressure on Leak Detector in Leak Detect Mode _____
Time in Leak Detect Mode at Operating Pressure _____
Name _____ Date _____

Product _____ PASS FAIL
Leak Detector Type _____
Drain Line Pressure to Zero Yes No
Adjust Flow Meter to 3 Gal/Hr. Yes No
Pressure on Leak Detector in Leak Detect Mode _____
Time in Leak Detect Mode at Operating Pressure _____
Name _____ Date _____

STAGE I ANNUAL INSPECTION

VERMONT DEPT. OF ENVIRONMENTAL CONSERVATION AIR QUALITY & CLIMATE DIVISION

This form includes the questions to be answered to complete the annual inspection of a Stage I vapor recovery system required by Section 5-253.5(d)(2) of the Air Pollution Control Regulations. Use of this form is optional – it is intended to be used in the field to record the information collected during the annual inspection. This information will be reported as part of the annual Underground Storage Tank Self Certification.

A. FACILITY INFORMATION:

UST Program Facility Identification #: _____ Facility: _____

Street Address : _____

City, State : _____

B. ANNUAL INSPECTION CHECK LIST FOR STAGE I VAPOR RECOVERY SYSTEMS:

The annual inspection is to be performed no sooner than 10 months after the prior annual inspection and the results reported as part of the annual Underground Storage Tank Self Certification. The numbering of the questions below corresponds to the numbering system in the Underground Storage Tank Self Certification.

11A01 - Is a drop tube installed in the fill pipe for each gasoline storage tank? Yes No

11A02 - Is your facility equipped for Stage I Vapor Recovery? (If you answer "yes" proceed to question 11A04) Yes No

11A03 - If the answer to 11A01 was "No", does your facility receive all gasoline deliveries from gasoline tank trucks with a capacity of <4000 gallons? Yes No (If the answer to question 11A02 was "No", the remaining questions don't apply to this facility).

11A04 - What type of Stage I vapor recovery is installed at your facility? Two Point Coaxial (single point)

11A05 - Is an intact pressure vacuum (P/V) valve installed on each gasoline storage tank vent pipe? Yes No

11A06 - Is an intact gasket present inside each fill adaptor cap? Yes No

11A07 - Does each fill adaptor cap seal tightly onto the fill adaptor? Yes No

11A08 - Is each fill adaptor threaded tightly onto the riser pipe? Yes No

11A09 - Is an intact gasket present inside each vapor adaptor cap? Yes No N/A

11A10 - Does the poppet valve of each vapor adaptor depress and reseat properly to make a tight seal with the valve seat? Yes No N/A

11A11 - Does each vapor adaptor cap seal tightly onto the vapor adaptor? Yes No N/A

11A12 - Is each vapor adaptor threaded tightly onto the riser pipe? Yes No N/A

11A13 - Does each in-tank monitor cap seal tightly? Yes No N/A

11A14 - Does the probe wire grommet seal tightly around the probe wire for each in-tank monitor? Yes No N/A

11A15 - If any spill bucket is equipped with a drain valve does it seal tightly? Yes No N/A