

**C-STORE CONTRACTING**  
**32 SAN REMO DRIVE**  
**S. BURLINGTON, VT 05403**  
**802-862-2500**  
**FAX 802-864-6234**

Over Short Check List.

TODAYS DATE \_\_\_\_\_  
Site \_\_\_\_\_ Address \_\_\_\_\_ City \_\_\_\_\_  
Month of Concern \_\_\_\_\_  
Date Investigation \_\_\_\_\_

Product \_\_\_\_\_

1. Check Dispensers by removing lower doors and verify everything is tight.  
**TURN ON PUMPS.** \_\_\_\_\_
2. Check Interstitials on Tanks (wet or dry?) \_\_\_\_\_
3. Check submersible, siphon and dispenser sumps for piping leaks (wet or dry?) \_\_\_\_\_
4. Check Tank Monitor for alarms (attach tank monitor printout) \_\_\_\_\_
5. Calibrate meters and list results on this form \_\_\_\_\_
5. Check Monitor Wells (if instructed) \_\_\_\_\_  
If none, state so \_\_\_\_\_

Name \_\_\_\_\_ Signature \_\_\_\_\_

Name \_\_\_\_\_ Signature \_\_\_\_\_